



DAT300 THE ELECTRICAL POWER SYSTEM

Stefan Lundberg
stefan.lundberg@chalmers.se

Department of Energy and Environment
Division of Electric Power Engineering
Chalmers University of technology


CHALMERS
UNIVERSITY OF TECHNOLOGY

History of the power systems


AC transmission was first demonstrated at an exhibition in Frankfurt am Main 1891

170 kW transferred 175 km from Lauffen hydropower station to the exhibition area at 13000-14700 V



CHALMERS
UNIVERSITY OF TECHNOLOGY


History of the power systems in Sweden



First 3-phase transmission system installed in Sweden between Hellsjön and Grängesberg 1893
voltage 9650 V, 70 Hz, 70 kW

First 400 kV system Harsprånget Hallsberg 1952


Series compensation introduced 1954



CHALMERS
UNIVERSITY OF TECHNOLOGY



Fundamentals of Electric Power

- Energy
 - Ability to perform work, [J], [Ws], [kWh] (1 kWh = 3.6 MJ)
- Voltage
 - Measured between two points [V], [kV]
 - Equivalent to pressure in a water pipe
- Current
 - Measure of rate of flow of charge through a conductor [A], [kA]
 - Equivalent to the rate of flow of water through a pipe.
 - Must have a closed circuit to have a current





CHALMERS
UNIVERSITY OF TECHNOLOGY

Direct Current (DC) / Alternating Current (AC)

$u(t) = U$
 $i(t) = I$

$u(t) = U_{peak} \cos(\omega t - \alpha)$
 $i(t) = I_{peak} \cos(\omega t - \beta)$
 $\omega = 2\pi f$

RMS = Root-Mean-Square

$$I_{RMS} = \sqrt{\frac{1}{T} \int_0^T i(t)^2 dt} = \frac{I_{peak}}{\sqrt{2}}$$



Only for sinusoidal waveforms

CHALMERS
UNIVERSITY OF TECHNOLOGY

Why is AC used?

The **two main** factors that formed the power system

- Transformer (only works on AC)
- Robust and cheap motor (rotating flux)

CHALMERS
UNIVERSITY OF TECHNOLOGY

Alternating Current (AC)

$u(t) = U_{peak} \cos(\omega t - \alpha)$
 $i(t) = I_{peak} \cos(\omega t - \beta)$
 $\omega = 2\pi f$

Express the sinusoidal voltage and current as complex rotating phasors and use RMS values for the amplitude

$u(t) = \sqrt{2} \operatorname{Re} \left\{ U_{RMS} e^{j(\omega t - \alpha)} \right\}$
 $i(t) = \sqrt{2} \operatorname{Re} \left\{ I_{RMS} e^{j(\omega t - \beta)} \right\}$

Since all phasors are rotating with the same speed, we select one as the reference and observe all others relative to this one. This gives that the rotation disappears and the voltage and currents can be expressed as complex number (constant)

$\underline{U} = U_{RMS} \angle \alpha$
 $\underline{I} = I_{RMS} \angle \beta$

CHALMERS
UNIVERSITY OF TECHNOLOGY

Impedance

consumes active power: $\underline{U}_R = R \underline{I}_R$
 consumes reactive power: $\underline{U}_L = j\omega L \underline{I}_L$
 produces reactive power: $\underline{U}_C = -j \frac{1}{\omega C} \underline{I}_C$

$u_R(t) = R i_R(t)$
 $u_L(t) = L \frac{di_L(t)}{dt}$
 $i_C(t) = C \frac{du_C(t)}{dt}$

$\underline{U}_R = R \underline{I}_R$
 $\underline{U}_L = j\omega L \underline{I}_L = jX_L \underline{I}_L$
 $X_L = \omega L$

$\underline{U}_C = -j \frac{1}{\omega C} \underline{I}_C = -jX_C \underline{I}_C$
 $X_C = \frac{1}{\omega C}$

CHALMERS
UNIVERSITY OF TECHNOLOGY

Why three phase system?

Tre enfassystem (left) vs. Ett trefassystem (right).
 Labels: Tre enfass-generatorer, Elnät, Belastning, En trefas-generator, $I_\Sigma = 0$.

CHALMERS
UNIVERSITY OF TECHNOLOGY

Three phase voltage and current

Voltage (solid), Current (dotted).
 Time axis: 0 to 0.02 s.
 Voltage axis: -400 to 400 V.

CHALMERS
UNIVERSITY OF TECHNOLOGY

Phasors for the voltages

$U_{L-L} = \sqrt{3} U_f$
 Line to Line (red arrow)
 Phase (to ground) (blue arrow)

CHALMERS
UNIVERSITY OF TECHNOLOGY

Power – Rate of energy flow [W]

$u(t) = \sqrt{2} U_{RMS} \cos(\omega t)$
 $i(t) = \sqrt{2} I_{RMS} \cos(\omega t - \varphi)$



Angle between voltage and current: $\varphi = \alpha - \beta$

Single phase | **Three phase**
 Instantaneous power: $p(t) = u(t)i(t)$ | $p(t) = u_R(t)i_R(t) + u_S(t)i_S(t) + u_T(t)i_T(t)$
 Average power: $P = \frac{1}{T} \int_0^T u(t)i(t) dt$ | $P = \frac{1}{T} \int_0^T [u_R(t)i_R(t) + u_S(t)i_S(t) + u_T(t)i_T(t)] dt$

Apparent power
 $S = U I^* = P + jQ$ [VA] | $S = 3 U_{L-L} I^* = P + jQ$

Active power
 $P = |U_{RMS}| |I_{RMS}| \cos \varphi$ [W] | $P = 3 |U_{RMS}| |I_{RMS}| \cos \varphi = \sqrt{3} |U_{L-L, RMS}| |I_{RMS}| \cos \varphi$

Reactive power
 $Q = |U_{RMS}| |I_{RMS}| \sin \varphi$ [VAr] | $Q = 3 |U_{RMS}| |I_{RMS}| \sin \varphi = \sqrt{3} |U_{L-L, RMS}| |I_{RMS}| \sin \varphi$



CHALMERS
UNIVERSITY OF TECHNOLOGY

Reactive power flow – What is reactive power?

Consider an alternating current I_{line} flowing in a line

- The current causes a magnetic field around the conductor
- The field strength is highest close to the conductor surface
- The field energy density is proportional to the square of the field strength
- The field is built up and eliminated with the double of the network frequency in each phase

CHALMERS
UNIVERSITY OF TECHNOLOGY

Reactive power flow – What is reactive power?

Consider a line segment of, for example, 100 km in a long transmission line

- The distance between the phases is about 10 m.
- It is not possible to transfer the energy directly between the neighboring phases.
- The energy must be transported to some place where the conductors are connected (a generator or a transformer).

CHALMERS
UNIVERSITY OF TECHNOLOGY

Reactive power flow – What is reactive power?

How much energy is involved?

Consider a line segment of 100 km and a current of 1 kA (rms value); the energy at the current peak is

$$W_{\phi} = \frac{1}{2} L_{line}^2 = \frac{1}{2} \cdot 0.1 \cdot (1000 \cdot \sqrt{2})^2 = 100 \text{ kJ}$$

It is the same energy needed to lift a 1500 kg car up to 7 meters.

This is done each 10 ms, in each phase.

CHALMERS
UNIVERSITY OF TECHNOLOGY

Reactive power flow – What is reactive power?

Due to the presence of the reactive power, the system cannot be used up to its thermal limit

Need for reactive power compensation for better utilization of the system

CHALMERS
UNIVERSITY OF TECHNOLOGY

Power flow

Active/reactive power at sending end E_s

$$P_s = \text{real}(\vec{E}_s \vec{I}^*) = E_s I_p = \frac{E_s E_r \sin \delta}{X_L}$$

$$Q_s = \text{imag}(\vec{E}_s \vec{I}^*) = E_s I_q = \frac{E_s (E_s - E_r \cos \delta)}{X_L}$$

Active/reactive power at receiving end E_r

$$P_r = \text{real}(\vec{E}_r \vec{I}^*) = \frac{E_r E_s \sin \delta}{X_L}$$

$$Q_r = \text{imag}(\vec{E}_r \vec{I}^*) = -\frac{E_r (E_r - E_s \cos \delta)}{X_L}$$

CHALMERS
UNIVERSITY OF TECHNOLOGY

Voltages at the ends of a transmission line (same phase)

Phase Angle Difference (δ) of Voltage Sinusoids at the Ends of a Transmission Line

s = 1 (sending end)
r = 2 (receiving end)

CHALMERS
UNIVERSITY OF TECHNOLOGY

s = 1 (sending end)
r = 2 (receiving end)

Power flow

$$\vec{I} = \frac{\vec{E}_1 - \vec{E}_2}{jX} = \frac{E_1 \sin \delta}{X} + j \frac{E_2 - E_1 \cos \delta}{X} = I_{p2} - jI_{q2}$$

Complex power to E_2 :

$$\vec{S}_2 = \vec{E}_2 \vec{I}^* = E_2 (I_{p2} + jI_{q2}) = P_2 + jQ_2$$

Active/reactive power to E_2 :

$$P_2 = E_2 I_{p2} = \frac{E_2 E_1 \sin \delta}{X}$$

$$Q_2 = E_2 I_{q2} = -\frac{E_2 (E_2 - E_1 \cos \delta)}{X}$$

Active power from E_1 to E_2 :

$$P = P_1 = P_2 = \frac{E_2 E_1 \sin \delta}{X}$$

Reactive power consumption of the transmission line:

$$\Delta Q = Q_1 - Q_2 = \frac{1}{X} (E_1^2 + E_2^2 - 2E_1 E_2 \cos \delta) = \frac{E_2^2}{X}$$

CHALMERS
UNIVERSITY OF TECHNOLOGY

Structure of the Electric Power System

CHALMERS
UNIVERSITY OF TECHNOLOGY

The Swedish grid comprises nearly 200 and 600 kV lines connecting major power stations and major cities (S.1.1).

Voltage	Physical length	Power
600 kV AC	5000 km	4000 MW
220 kV AC	10000 km	10000 MW
130 kV AC	40000 km	4000 MW
10 kV AC	100000 km	10000 MW
0.4 kV AC	1000000 km	10000 MW

- Transmission 400, 220 kV
- Regionalnät 130 kV
- Distributionsnät 70, 40, 30, 20, 10 kV
- Kunder 400 V (Industri 10-130 kV)

Power balancing

Source: Svenska Kraftnät







CHALMERS
UNIVERSITY OF TECHNOLOGY




What happens if the turbine power does not match the load power?

Power balancing

Source: Svenska Kraftnät

$$\left. \begin{aligned} J \frac{d\omega}{dt} &= T_{\text{turbine}} - T_{\text{gen}} \\ P_{\text{turbine}} &= \omega T_{\text{turbine}} \\ P_{\text{gen}} &= \omega T_{\text{gen}} \\ P_{\text{load}} &\approx P_{\text{gen}} \\ \omega &= \frac{2\pi f_{\text{grid}}}{n_p} \end{aligned} \right\} \Rightarrow J \frac{4\pi^2}{n_p^2} \frac{df_{\text{grid}}}{dt} = \frac{P_{\text{turbine}} - P_{\text{gen}}}{f_{\text{grid}}}$$





CHALMERS
UNIVERSITY OF TECHNOLOGY

Electric energy production in Sweden:

145,0 TWh år 2007 (v 65,5; k 64,3)

146,0 TWh år 2008 (v 68,6; k 61,3; v 2,0)

133,7 TWh år 2009 (v 65,3; k 50,0; v 2,5)

144,9 TWh år 2010 (v 66,8; k 55,6; v 3,5)


146,9 TWh år 2011 (v 66,0; k 58,0; v 6,1)


v=Hydro power v=Wind power
k=nuclear power

CHALMERS
UNIVERSITY OF TECHNOLOGY

Installed peak power in Sweden 2011.12.31, MW_{el}

Hydro power	16 197
Wind power	2 899
Nuclear power	9 363
Other thermal power	7 988
Σ	36 447





The End

Do you have any questions?